

Water-Based Fire Protection System Test Code List

004. Periodic Inspections:

004.01. In order to assure compliance with, and aid in the implementation of state and local building laws and regulations, all water-based fire protection systems shall be inspected annually by a Water-Based Fire Protection System Contractor's Representative. Small domestic systems with two (2) sprinklers or fewer are not required to be inspected annually.

004.02. The currently adopted edition of NFPA - No. 25, "Standards for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems" shall provide the basis for the inspection procedures to be performed.

004.03. Upon completion of the annual inspection, the Water-Based Fire Protection System Contractor's Representative shall complete a Nebraska State Fire Marshal Fire Sprinkler Inspection Form, see ATTACHMENT "C". The form is to be signed by a qualified inspector and the building owner or a representative of the building owner. Each inspection report shall bear the serial numbers of the identification tag. A copy of the form is to be maintained at the system riser with a duplicate forwarded to the State Fire Marshal's Office.

Please refer to the following National Fire Protection Association (NFPA) Codes. Information about or the examination of these documents are available from the State Fire Marshal's Office in Lincoln, Albion, or North Platte and the delegated authority in Beatrice, Bellevue, Grand Island, Lincoln, Norfolk, North Platte, Omaha, and Scottsbluff.

1. Installation of Sprinkler Systems - NFPA 13 (1994 Edition)
2. Sprinkler Systems in One & Two Family Dwellings and Manufactured Homes - NFPA 13D (1994 Edition)
3. Sprinkler Systems in Residential Occupancies Up to & Including Four Stories in Height - NFPA 13R (1994 Edition)
4. Installation of Standpipe & Hose System - NFPA 14 (1996 Edition)
5. Water Spray Fixed Systems - NFPA 15 (1990 Edition)
6. Deluge Foam-Water Sprinkler Systems & Foam-Water Spray Systems - NFPA 16 (1995 Edition)
7. Installation of Closed-Head Foam Water Sprinkler Systems - NFPA 16A (1994 Edition)
8. Installation of Centrifugal Fire Pumps - NFPA 20 (1993 Edition)
9. Water Tanks for Private Fire Protection - NFPA 22 (1996 Edition)
10. Installation of Private Fire Service Mains - NFPA 24 (1995 Edition)
11. Water-Based Fire Protection Systems - NFPA 25 (1995 Edition)
12. General Storage - NFPA 231 (1995 Edition)
13. Rack Storage of Materials - NFPA 231C (1995 Edition)